

4.09 Removal of Class II Standpipe Hose Cabinets in Sprinkler Retrofitted Buildings (2016)

Reference: 2016 SFFC 901.8

- I. Section 901.8 of the SFFC requires written approval from the fire code official in order to remove existing fire appliances. In order to speed the permit process, buildings subject to the San Francisco High-rise Sprinkler Ordinance will be permitted to remove Class II Standpipe hose cabinets on individual floors after they have been fully sprinklered. The applicant shall state his or her intention to remove the hose cabinets on the approved sprinkler plans.
- II. Buildings not subject to the ordinance will continue to require written approval from the fire code official in order to remove any fire appliance. These written requests will be considered on a case-by-case basis.
- III. Removal of Class II standpipes requires an approved building permit.